

FORMAL SITE PLAN REVIEW RESULTS
Growth Management Department
Regulatory Review

Meeting held March 12, 2009
9:00 am-2nd Floor Hearing Room

SPR 009-09

New England Water Storage Tank
COMM Fire District/Water Department
345 Old Stage Road, Centerville
(Access thru 319 Old Stage Road)
Maps 190 & 189, Parcels 107 & 037 respectively
Zoning District RC, RPOD

Proposal:

Construction of new 1.5 million gallon composite (concrete pedestal, steel tank) elevated water storage tank, adjacent to an existing 250,000 gallon steel water tank. Demolition of existing tank to be performed once new tank is on-line.

Status: Approved as presented. Written protocol to be provided for 2nd access.